Goverment of West Bengal

Office of the Divisional Fire Officer

West Bengal Fire & Emergency Services
Government Of West Bengal Office Of The Divisional Fire Officer, North Dinajpur, West Bengal Fire & Emergency Services Raiganj Fire Station, College Para, P.O.:- Raiganj, Pin :- 733134

Memo No.:FSR/0125186200600657 **Date : 09-02-2026**

From :
Divisional Fire Officer
North Dinajpur Division,
West Bengal Fire & Emergency Services

To :
Daffodils English Academy, 1) Smt. Sumita Bhowmik 2) Smt. Dipanwita Roy
Plot no-3206,3207,3208,3209,3210, 3211, LR Kh no-4177,4178, JL No- 02, Adalgachh, Ramganj- 2 GP, PS- Islampur, Dist â Uttar Dinajpur, Pin-733207

Sub : Fire Safety Certificate for existing construction of G+2 storied Educational Building under group of educational in the name of Daffodils English Academy, 1) Smt. Sumita Bhowmik 2) Smt. Dipanwita Roy at the Premises no -MOUZA- PHULHARA,SHEET NO – 02, L.R. Plot No.: 3206, 3207, 3208, 3209, 3210, 3211, L.R. Kh. No.: 4177,4178, J.L. No.: 02, Adalgachh, Under Ramganj II Gram Panchayat, P.S.: Islampur, Dist.: North Dinajpur, Pin.: 733207.

This is in reference to your AIN 211892606300009678 dated 23-Jan-2026 regarding Fire Safety Certificate for existing construction of G+2 storied Educational Building under group of educational in the name of Daffodils English Academy, 1) Smt. Sumita Bhowmik 2) Smt. Dipanwita Roy at the Premises no -MOUZA- PHULHARA,SHEET NO – 02, L.R. Plot No.: 3206, 3207, 3208, 3209, 3210, 3211, L.R. Kh. No.: 4177,4178, J.L. No.: 02, Adalgachh, Under Ramganj II Gram Panchayat, P.S.: Islampur, Dist.: North Dinajpur, Pin.: 733207.

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

Recommendation:

* One Stand by pump, auto pannel board shall be installed within 3months.
1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2.To eliminate risk of Fire Hazards, Good Housekeeping both for insides and outside of the building shall be

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892606300009678

Principal
DAFFODILS ENGLISH ACADEMY
P.O. Ramganj, U/Dinajpur-733207 (W.B.)

Secretary
DAFFODILS ENGLISH ACADEMY
P.O. Ramganj, U/Dinajpur-733207 (W.B.)

strictly maintained.
3. Existing Electrical wiring of the whole building shall have to be carefully checked for any ware and tear in there, particularly lines above false ceiling & ducts.
4. The notice of Fire Fighting and evacuation from the building shall be prepared and displayed at all vulnerable of the building.
5. Regular Mock fire Practices and evacuation drill should be conducted periodically by participation of all the occupants of the building and for this purpose a special crew should be formed.
6. A Crew of trained fire man should be maintained round the clock for the safety of the building.
7. Arrangement shall have to make for regular checking and testing of the fire fighting system in the building to keep the system in good working condition.
8. Periodical flashing of water in the Hydrant shall be made to maintain the efficiency of the above mentioned system.
9.The employees and security staff shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of Fire and Testing.
10. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
11. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
12. Transformer and Switch Gear room shall be protected with automatic Co2 or D.C.P. Fire extinction conforming I.S. Specification.
13. Directional sign of escape route should be displaced prominently (Auto glow sign) at all conspicuous place of the building as per clause 5.5 of the N.B. code.
14. Fire control room including a closed circuit T.V system and Fire alarm panel will have to be install, which observes all floor of the building.
15.Adequate number of NO SMOKING boards should be displaying surrounding the premises.
16.The Fire Safety Audit to be conducted at in a regular interval and to record in the Fire Prevention Maintenance register.
17. The Fire Safety Certificate is valid for three years and has to be renewed after three years from the date of issue of this letter As per Govt.of West Bengal Vide Notification No-629_L Dated-17/04/2018..
18. After three years a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services on the basis of performance of all the Life & Fire Safety arrangements and installations of the building.

Memo No.:FSR/012518620060065 7

Valid Upto : 07-Feb-2029

Signature valid
Digitally Signed.
Name: SHRI NARAYAN BARMAN
Date: 09-Feb-2019 16:11:26
Reason: D-Sign
Location: E-Dist 2.0
Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892606300009678

Principal
DAFFODILS ENGLISH ACADEMY
P.O. Ramganj, U/Dinajpur-733207 (W.B.)

Secretary
DAFFODILS ENGLISH ACADEMY
P.O. Ramganj, U/Dinajpur-733207 (W.B.)